

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833
Report April 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170333895	Drinking water Delivery Tap 1	27.04.2017	10:00	14,0	colorless, clear	0,94	7,57	0	0	0	0	0	0
170333896	Drinking water Delivery Tap 2	27.04.2017	09:50	14,0	colorless, clear	0,92	7,58	0	0	0	0	0	0
170333897	Drinking water Delivery Tap 3	27.04.2017	09:50	14,0	colorless, clear	0,97	7,57	0	0	0	0	0	0
170333898	Drinking water Delivery Tap 4	27.04.2017	09:55	14,0	colorless, clear	1,09	7,55	0	0	0	0	0	0
170333899	Tank vehicle KWW 32, clutch pipe delivery	27.04.2017	09:35	15,4	colorless, clear	0,72	7,59	0	0	0	0	0	0
170334052	Tank vehicle KWW 34, clutch pipe delivery	27.04.2017	08:45	14,5	colorless, clear	0,96	7,49	0	0	0	0	0	0
170334053	Tank vehicle KWW 35, clutch pipe delivery	27.04.2017	09:05	13,5	colorless, clear	0,59	7,83	0	0	0	0	0	0
170334055	Tank vehicle KWW 37, clutch pipe delivery	27.04.2017	09:25	14,0	colorless, clear	0,87	7,81	0	0	0	0	0	0
170334056	Tank vehicle KWW 38, clutch pipe delivery	27.04.2017	09:15	13,2	colorless, clear	0,61	7,73	0	0	0	0	0	0
170334057	Tank vehicle KWW 39, clutch pipe delivery	27.04.2017	09:35	15,0	colorless, clear	0,47	7,73	0	0	0	0	0	0
170334058	Tank vehicle KWW 40, clutch pipe delivery	27.04.2017	09:20	14,5	colorless, clear	0,69	7,75	0	0	0	0	0	0
170334059	Tank vehicle KWW 41, clutch pipe delivery	27.04.2017	08:55	13,8	colorless, clear	0,64	7,80	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833
Report April 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170334062	Tank vehicle KWW 42, clutch pipe delivery	27.04.2017	09:40	14,8	colorless, clear	0,77	7,81	0	0	0	0	0	0
170334063	Tank vehicle KWW 43, clutch pipe delivery	27.04.2017	09:10	13,9	colorless, clear	0,80	7,73	0	0	0	0	0	0
170334064	Tank vehicle KWW 44, clutch pipe delivery	27.04.2017	09:00	14,3	colorless, clear	0,78	7,75	0	0	0	0	0	0
170334065	Tank vehicle KWW 45, clutch pipe delivery	27.04.2017	09:30	13,8	colorless, clear	0,87	7,70	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, May 08, 2017