

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804  
Report August 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170791090	Drinking water Delivery Tap 1	30.08.2017	08:20	19,3	colorless, clear	0,78	7,57	0	1	0	0	0	0
170791091	Drinking water Delivery Tap 2	30.08.2017	08:45	19,3	colorless, clear	0,85	7,55	0	0	0	0	0	0
170791092	Drinking water Delivery Tap 3	30.08.2017	09:50	19,6	colorless, clear	0,32	7,60	0	0	0	0	0	0
170791093	Drinking water Delivery Tap 4	30.08.2017	10:15	19,8	colorless, clear	0,56	7,58	0	0	0	0	0	0
170791094	Tank vehicle KWW 32, clutch pipe delivery	30.08.2017	09:15	19,6	colorless, clear	0,72	7,56	0	0	0	0	0	0
170791095	Tank vehicle KWW 33, clutch pipe delivery	30.08.2017	09:36	20,2	colorless, clear	0,66	7,54	0	0	0	0	0	0
170791096	Tank vehicle KWW 34, clutch pipe delivery	30.08.2017	09:40	21,2	colorless, clear	0,68	7,64	0	0	0	0	0	0
170791097	Tank vehicle KWW 35, clutch pipe delivery	30.08.2017	09:55	19,8	colorless, clear	0,66	7,78	0	0	0	0	0	0
170791098	Tank vehicle KWW 36, clutch pipe delivery	30.08.2017	09:45	20,0	colorless, clear	0,68	7,56	0	0	0	0	0	0
170791099	Tank vehicle KWW 37, clutch pipe delivery	30.08.2017	10:00	20,0	colorless, clear	0,72	7,60	0	0	0	0	0	0
170791100	Tank vehicle KWW 38, clutch pipe delivery	30.08.2017	09:28	24,6	colorless, clear	0,14	7,98	0	0	0	0	0	0
170791151	Tank vehicle KWW 39, clutch pipe delivery	30.08.2017	09:00	19,3	colorless, clear	0,64	7,84	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804  
Report August 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170791152	Tank vehicle KWW 40, clutch pipe delivery	30.08.2017	10:05	20,4	colorless, clear	0,62	7,60	0	0	0	0	-	0
170791153	Tank vehicle KWW 41, clutch pipe delivery	30.08.2017	10:08	22,6	colorless, clear	0,64	7,52	0	0	0	0	0	0
170791154	Tank vehicle KWW 42, clutch pipe delivery	30.08.2017	09:20	22,0	colorless, clear	0,60	7,58	0	1	0	0	0	0
170791155	Tank vehicle KWW 43, clutch pipe delivery	30.08.2017	09:32	20,8	colorless, clear	0,65	7,72	0	0	0	0	0	0
170791156	Tank vehicle KWW 44, clutch pipe delivery	30.08.2017	09:25	19,6	colorless, clear	0,74	7,55	0	0	0	0	0	0
170791157	Tank vehicle KWW 45, clutch pipe delivery	30.08.2017	09:10	21,8	colorless, clear	0,59	7,80	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, September 07, 2017