

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 13.12.2017

Montag, 8. Januar 2018

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-33 clutch pipe delivery	6,5	7,5	0,64	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	3,6	8,0	0,05	0	72	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	5,0	7,7	0,31	0	2	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	10,1	7,6	0,64	0	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	8,9	7,7	0,70	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	11,7	7,7	0,64	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	8,1	7,8	0,62	0	1	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	10,1	7,7	0,69	1	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	9,2	7,6	0,70	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	9,6	7,0	0,69	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	9,0	7,5	0,85	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	11,4	7,5	0,30	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	11,2	7,1	0,56	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	11,1	7,5	0,61	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	11,1	7,2	0,47	0	0	0	0	0	0

Bemerkungen: