

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833**  
**Report February 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170156832	Drinking water Delivery Tap 1	23.02.2017	09:10	9,2	colorless, clear	0,54	7,50	0	0	0	0	0	0
170156833	Drinking water Delivery Tap 2	23.02.2017	09:15	9,2	colorless, clear	0,96	7,50	0	0	0	0	0	0
170156834	Drinking water Delivery Tap 3	23.02.2017	09:20	9,2	colorless, clear	1,52	7,40	0	0	0	0	0	0
170156835	Drinking water Delivery Tap 4	23.02.2017	09:25	9,2	colorless, clear	0,91	7,50	0	0	0	0	0	0
170156836	Tank vehicle KWW 32, clutch pipe delivery	23.02.2017	08:40	10,8	colorless, clear	0,68	7,80	0	0	0	0	0	0
170156844	Tank vehicle KWW 33, clutch pipe delivery	23.02.2017	09:00	11,4	colorless, clear	0,63	7,50	0	0	0	0	0	0
170156845	Tank vehicle KWW 34, clutch pipe delivery	23.02.2017	09:05	11,0	colorless, clear	0,65	7,80	0	0	0	0	0	0
170156846	Tank vehicle KWW 35, clutch pipe delivery	23.02.2017	08:45	10,2	colorless, clear	0,60	7,70	0	0	0	0	0	0
170156847	Tank vehicle KWW 36, clutch pipe delivery	23.02.2017	08:40	10,6	colorless, clear	0,61	7,60	0	0	0	0	0	0
170156849	Tank vehicle KWW 38, clutch pipe delivery	23.02.2017	08:30	10,8	colorless, clear	0,63	7,80	0	0	0	0	0	0
170156850	Tank vehicle KWW 39, clutch pipe delivery	23.02.2017	08:25	10,8	colorless, clear	0,67	7,80	0	0	0	0	0	0
170156951	Tank vehicle KWW 40, clutch pipe delivery	23.02.2017	08:36	11,0	colorless, clear	0,59	7,80	2	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833  
Report February 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170156954	Tank vehicle KWW 41, clutch pipe delivery	23.02.2017	08:50	9,8	colorless, clear	0,63	7,60	0	1	0	0	0	0
170156955	Tank vehicle KWW 42, clutch pipe delivery	23.02.2017	09:40	10,2	colorless, clear	0,70	7,50	0	2	0	0	0	0
170156956	Tank vehicle KWW 43, clutch pipe delivery	23.02.2017	08:20	10,0	colorless, clear	0,63	7,90	0	0	0	0	0	0
170156957	Tank vehicle KWW 44, clutch pipe delivery	23.02.2017	09:05	10,6	colorless, clear	0,64	7,70	0	0	0	0	0	0
170156979	Tank vehicle KWW 45, clutch pipe delivery	23.02.2017	08:55	10,4	colorless, clear	0,58	7,70	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, March 01, 2017

\_\_\_\_\_