

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833  
Report January 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
161208276	Drinking water Delivery Tap 1	25.01.2017	09:35	10,0	colorless, clear	1,30	0	0	0	0	0	0
161208278	Drinking water Delivery Tap 2	25.01.2017	09:38	9,2	colorless, clear	1,00	0	0	0	0	0	0
161208280	Drinking water Delivery Tap 3	25.01.2017	09:48	8,2	colorless, clear	1,06	0	0	0	0	0	0
161208282	Drinking water Delivery Tap 4	25.01.2017	10:00	9,2	colorless, clear	0,98	0	0	0	0	0	0
161208284	Tank vehicle KWW 32, clutch pipe delivery	25.01.2017	10:08	7,7	colorless, clear	1,40	0	0	0	0	0	0
161208288	Tank vehicle KWW 33, clutch pipe delivery	25.01.2017	09:45	8,4	colorless, clear	1,20	0	0	0	0	0	0
161208290	Tank vehicle KWW 34, clutch pipe delivery	25.01.2017	09:25	12,2	colorless, clear	1,44	0	0	0	0	0	0
161208292	Tank vehicle KWW 35, clutch pipe delivery	25.01.2017	09:50	7,5	colorless, clear	1,12	0	0	0	0	0	0
161208294	Tank vehicle KWW 36, clutch pipe delivery	25.01.2017	09:54	7,8	colorless, clear	1,20	0	0	0	0	0	0
161208296	Tank vehicle KWW 37, clutch pipe delivery	25.01.2017	09:10	9,0	colorless, clear	1,24	0	0	0	0	0	0
161208300	Tank vehicle KWW 39, clutch pipe delivery	25.01.2017	10:40	8,6	colorless, clear	1,34	0	0	0	0	0	0
161208402	Tank vehicle KWW 40, clutch pipe delivery	25.01.2017	09:15	11,2	colorless, clear	1,26	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833  
Report January 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
161208413	Tank vehicle KWW 41, clutch pipe delivery	25.01.2017	09:40	7,4	colorless, clear	1,10	0	0	0	0	0	0
161208517	Tank vehicle KWW 42, clutch pipe delivery	25.01.2017	10:30	7,2	colorless, clear	1,32	0	0	0	0	0	0
161208519	Tank vehicle KWW 43, clutch pipe delivery	25.01.2017	09:00	9,5	colorless, clear	1,40	0	0	0	0	0	0
161208621	Tank vehicle KWW 44, clutch pipe delivery	25.01.2017	09:23	10,0	colorless, clear	1,28	0	0	0	0	0	0
161208623	Tank vehicle KWW 45, clutch pipe delivery	25.01.2017	09:08	8,0	colorless, clear	1,20	0	0	0	0	0	0

**Assessment:**

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

**SGS INSTITUT FRESENIUS GmbH**

Taunusstein, February 03, 2017 \_\_\_\_\_