

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833
Report July 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170671068	Drinking water Delivery Tap 1	26.07.2017	09:50	19,0	colorless, clear	0,86	7,64	0	0	0	0	0	0
170671069	Drinking water Delivery Tap 2	26.07.2017	09:30	19,0	colorless, clear	0,53	7,65	0	0	0	0	0	0
170671071	Drinking water Delivery Tap 3	26.07.2017	09:25	18,0	colorless, clear	0,16	7,70	0	0	0	0	0	0
170671072	Drinking water Delivery Tap 4	26.07.2017	09:20	18,6	colorless, clear	0,52	7,60	0	0	0	0	0	0
170671073	Tank vehicle KWW 32, clutch pipe delivery	26.07.2017	08:45	17,0	colorless, clear	0,24	7,68	0	0	0	0	0	0
170671075	Tank vehicle KWW 33, clutch pipe delivery	26.07.2017	09:12	17,6	colorless, clear	0,42	7,94	0	0	0	0	0	0
170671076	Tank vehicle KWW 34, clutch pipe delivery	26.07.2017	08:50	18,6	colorless, clear	0,44	7,76	0	0	0	0	0	0
170671077	Tank vehicle KWW 35, clutch pipe delivery	26.07.2017	09:42	17,2	colorless, clear	0,36	7,80	0	0	0	0	0	0
170671078	Tank vehicle KWW 36, clutch pipe delivery	26.07.2017	09:38	18,6	colorless, clear	0,56	7,76	0	0	0	0	0	0
170671079	Tank vehicle KWW 37, clutch pipe delivery	26.07.2017	10:00	18,6	colorless, clear	0,50	7,93	0	0	0	0	0	0
170671083	Tank vehicle KWW 39, clutch pipe delivery	26.07.2017	08:58	19,2	colorless, clear	0,40	7,74	0	0	0	0	0	0
170671084	Tank vehicle KWW 40, clutch pipe delivery	26.07.2017	09:15	18,6	colorless, clear	0,50	7,92	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833
Report July 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170671085	Tank vehicle KWW 41, clutch pipe delivery	26.07.2017	09:35	18,8	colorless, clear	0,46	7,86	0	0	0	0	0	0
170671086	Tank vehicle KWW 42, clutch pipe delivery	26.07.2017	08:35	20,0	colorless, clear	0,46	7,68	0	0	0	0	0	0
170671087	Tank vehicle KWW 43, clutch pipe delivery	26.07.2017	08:55	18,6	colorless, clear	0,36	7,82	0	0	0	0	0	0
170671088	Tank vehicle KWW 44, clutch pipe delivery	26.07.2017	09:05	18,0	colorless, clear	0,45	7,86	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, August 01, 2017