

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

## Fraport drinking water tank vehicles and delivery

Sampling date 28.06.2017

Donnerstag, 6. Juli 2017

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-33 clutch pipe delivery	21,7	7,7	0,95	0	0	0	0	0	0
Tank vehicle KWW-34 clutch pipe delivery	20,6	8,0	1,01	0	1	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	20,1	7,8	1,01	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	20,9	8,1	0,99	0	1	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	19,0	7,6	0,98	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	20,9	8,0	1,00	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	22,1	8,2	0,84	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	21,6	7,9	0,98	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	19,2	7,6	1,07	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	20,5	7,9	0,96	1	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	20,3	7,8	1,00	0	1	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	20,3	8,0	1,01	0	0	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	20,6	8,0	0,98	0	1	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	18,7	7,6	0,98	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	18,7	7,6	1,17	1	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	18,6	7,7	0,75	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	18,9	7,6	0,72	0	1	0	0	0	0

**Bemerkungen:**