

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833
Report May 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170460924	Drinking water Delivery Tap 1	31.05.2017	09:20	16,8	colorless, clear	0,64	7,42	0	0	0	0	0	0
170460925	Drinking water Delivery Tap 2	31.05.2017	09:26	17,0	colorless, clear	0,64	7,40	0	0	0	0	0	0
170460926	Drinking water Delivery Tap 3	31.05.2017	09:54	17,0	colorless, clear	0,43	7,40	0	0	0	0	0	0
170460927	Drinking water Delivery Tap 4	31.05.2017	10:00	16,6	colorless, clear	0,76	7,32	0	0	0	0	0	0
170460928	Tank vehicle KWW 32, clutch pipe delivery	31.05.2017	08:55	17,0	colorless, clear	0,76	7,44	0	0	0	0	0	0
170460929	Tank vehicle KWW 33, clutch pipe delivery	31.05.2017	08:45	17,6	colorless, clear	0,70	7,45	0	0	0	0	0	0
170460930	Tank vehicle KWW 34, clutch pipe delivery	31.05.2017	08:42	17,4	colorless, clear	0,75	7,44	0	0	0	0	0	0
170460931	Tank vehicle KWW 35, clutch pipe delivery	31.05.2017	08:50	20,0	colorless, clear	0,58	7,72	0	0	0	0	0	0
170460932	Tank vehicle KWW 36, clutch pipe delivery	31.05.2017	09:10	19,4	colorless, clear	0,62	7,56	0	0	0	0	0	0
170460933	Tank vehicle KWW 37, clutch pipe delivery	31.05.2017	09:04	18,6	colorless, clear	0,72	7,54	0	0	0	0	0	0
170460934	Tank vehicle KWW 38, clutch pipe delivery	31.05.2017	09:00	17,4	colorless, clear	0,57	7,46	0	0	0	0	0	0
170460935	Tank vehicle KWW 39, clutch pipe delivery	31.05.2017	09:50	19,8	colorless, clear	0,51	7,72	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500541833
Report May 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
170460936	Tank vehicle KWW 40, clutch pipe delivery	31.05.2017	09:42	20,6	colorless, clear	0,62	7,74	0	0	0	0	0	0
170460937	Tank vehicle KWW 41, clutch pipe delivery	31.05.2017	09:30	19,4	colorless, clear	0,63	7,62	0	0	0	0	0	0
170460938	Tank vehicle KWW 42, clutch pipe delivery	31.05.2017	09:35	18,0	colorless, clear	0,80	7,40	0	0	0	0	0	0
170460939	Tank vehicle KWW 43, clutch pipe delivery	31.05.2017	08:40	18,4	colorless, clear	0,57	7,55	0	0	0	0	0	0
170460940	Tank vehicle KWW 44, clutch pipe delivery	31.05.2017	08:58	20,5	colorless, clear	0,52	7,58	0	0	0	0	0	0
170460941	Tank vehicle KWW 45, clutch pipe delivery	31.05.2017	09:45	18,4	colorless, clear	0,70	7,62	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, June 08, 2017