

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report November 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
171050725	Drinking water Delivery Tap 1	29.11.2017	08:30	11,8	colorless, clear	0,67	7,54	0	0	0	0	0	0
171050726	Drinking water Delivery Tap 2	29.11.2017	08:55	11,4	colorless, clear	0,64	7,57	0	0	0	0	0	0
171050727	Drinking water Delivery Tap 3	29.11.2017	09:20	11,5	colorless, clear	0,86	7,56	0	0	0	0	0	0
171050728	Drinking water Delivery Tap 4	29.11.2017	09:30	11,8	colorless, clear	0,37	7,68	0	0	0	0	0	0
171050730	Tank vehicle KWW 33, clutch pipe delivery	29.11.2017	08:20	12,0	colorless, clear	0,66	7,56	0	0	0	0	0	0
171050731	Tank vehicle KWW 34, clutch pipe delivery	29.11.2017	08:00	10,0	colorless, clear	0,62	7,53	0	0	0	0	0	0
171050732	Tank vehicle KWW 35, clutch pipe delivery	29.11.2017	09:00	10,8	colorless, clear	0,50	7,79	0	0	0	0	0	0
171050733	Tank vehicle KWW 36, clutch pipe delivery	29.11.2017	09:05	10,0	colorless, clear	0,47	7,76	0	0	0	0	0	0
171050734	Tank vehicle KWW 37, clutch pipe delivery	29.11.2017	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
171050735	Tank vehicle KWW 38, clutch pipe delivery	29.11.2017	08:45	10,5	colorless, clear	0,53	7,80	0	0	0	0	0	0
171050736	Tank vehicle KWW 39, clutch pipe delivery	29.11.2017	08:25	11,8	colorless, clear	0,67	7,57	0	0	0	0	0	0
171050737	Tank vehicle KWW 40, clutch pipe delivery	29.11.2017	08:40	11,4	colorless, clear	0,61	7,66	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report November 2017**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
171050738	Tank vehicle KWW 41, clutch pipe delivery	29.11.2017	08:50	10,0	colorless, clear	0,72	7,72	0	0	0	0	0	0
171050739	Tank vehicle KWW 42, clutch pipe delivery	29.11.2017	08:10	6,8	colorless, clear	0,40	7,88	0	0	0	0	0	0
171050740	Tank vehicle KWW 43, clutch pipe delivery	29.11.2017	08:15	8,6	colorless, clear	0,52	7,77	0	0	0	0	0	0
171050741	Tank vehicle KWW 44, clutch pipe delivery	29.11.2017	08:35	11,5	colorless, clear	0,60	7,62	0	0	0	0	0	0
171050742	Tank vehicle KWW 45, clutch pipe delivery	29.11.2017	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, December 06, 2017 _____