

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV 2001) from Mai 21st 2001 (BGBl. I p. 959) published on November 28th 2011 (BGBl. I p. 2370)

Fraport drinking water tank vehicles and delivery

Sampling date 28.09.2017

Mittwoch, 4. Oktober 2017

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 100	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-34 clutch pipe delivery	16,7	8,1	0,59	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	17,1	8,1	0,52	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	17,2	8,0	0,49	0	2	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	16,6	7,8	0,54	0	0	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	16,8	7,9	0,57	0	0	0	0	0	0
Tank vehicle KWW-40 clutch pipe delivery	17,4	8,2	0,33	0	0	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	16,9	7,9	0,46	0	1	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	17,6	7,9	0,45	0	0	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	16,7	8,0	0,48	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	16,7	8,0	0,46	0	0	0	0	0	0
Tank vehicle KWW-45 clutch pipe delivery	16,9	8,3	0,48	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	16,9	7,7	1,05	1	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	16,7	7,9	0,52	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	16,6	8,0	0,77	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	16,6	8,1	0,48	0	0	0	0	0	0

Bemerkungen: