

Official drinking water examination conformable to the german drinking water regulations §§ 18 und 19 (TrinkwV)  
published on March 28th 2016, last changed on 3rd January 2018

## Fraport drinking water tank vehicles and delivery

Sampling date 12.12.2018

Dienstag, 18. Dezember 2018

Sample designation	Water temperature [°C]	pH-value ≥6,5 und ≤9,5	free chlorine [mg/l]	colony count at 22°C	colony count at 36°C	Escherichia coli	Coliforms	Pseudomonas aeruginosa	Enterococcus
				[KBE/ml] limit value 1000*	[KBE/ml] limit value 100	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0	[KBE/100ml] limit value 0
Tank vehicle KWW-34 clutch pipe delivery	11,2	7,5	0,74	0	0	0	0	0	0
Tank vehicle KWW-35 clutch pipe delivery	10,9	7,6	1,05	0	0	0	0	0	0
Tank vehicle KWW-36 clutch pipe delivery	12,0	7,7	0,50	1	0	0	0	0	0
Tank vehicle KWW-37 clutch pipe delivery	10,5	7,7	0,74	0	0	0	0	0	0
Tank vehicle KWW-38 clutch pipe delivery	11,2	7,9	0,79	0	1	0	0	0	0
Tank vehicle KWW-39 clutch pipe delivery	8,3	7,7	0,78	0	1	0	0	0	0
Tank vehicle KWW-41 clutch pipe delivery	11,6	7,8	0,64	0	0	0	0	0	0
Tank vehicle KWW-42 clutch pipe delivery	9,5	7,4	0,79	0	5	0	0	0	0
Tank vehicle KWW-43 clutch pipe delivery	11,2	7,5	0,69	0	0	0	0	0	0
Tank vehicle KWW-44 clutch pipe delivery	11,2	7,8	0,64	0	0	0	0	0	0
Tank vehicle KWW-46 clutch pipe delivery	7,5	7,8	0,78	0	0	0	0	0	0
Drinking water delivery tap 01 clutch pipe delivery	12,0	7,8	0,71	0	0	0	0	0	0
Drinking water delivery tap 02 clutch pipe delivery	12,3	7,8	0,24	0	0	0	0	0	0
Drinking water delivery tap 03 clutch pipe delivery	11,9	7,7	0,78	0	0	0	0	0	0
Drinking water delivery tap 04 clutch pipe delivery	12,1	7,7	0,47	0	0	0	0	0	0

\* Limit value for sample designations like "Übergabestelle": 20 KBE

**Bemerkungen:**