

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report January 2018

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
171377342	Drinking water Delivery Tap 1	30.01.2018	10:10	9,5	colorless, clear	0,56	7,63	0	0	0	0	0	0
171377343	Drinking water Delivery Tap 2	30.01.2018	10:05	9,6	colorless, clear	0,90	7,68	0	1	0	0	0	0
171377344	Drinking water Delivery Tap 3	30.01.2018	09:10	10,3	colorless, clear	0,34	7,66	0	0	0	0	0	0
171377354	Drinking water Delivery Tap 4	30.01.2018	09:00	10,2	colorless, clear	1,00	7,60	0	0	0	0	0	0
171377355	Tank vehicle KWW 33, clutch pipe delivery	30.01.2018	09:15	10,2	colorless, clear	0,66	7,94	0	0	0	0	0	0
171377356	Tank vehicle KWW 34, clutch pipe delivery	30.01.2018	09:50	9,2	colorless, clear	0,74	7,76	0	0	0	0	0	0
171377357	Tank vehicle KWW 35, clutch pipe delivery	30.01.2018	09:35	9,1	colorless, clear	0,60	7,96	0	0	0	0	0	0
171377358	Tank vehicle KWW 36, clutch pipe delivery	30.01.2018	08:50	10,0	colorless, clear	0,50	7,74	0	0	0	0	0	0
171377359	Tank vehicle KWW 37, clutch pipe delivery	30.01.2018	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
171377360	Tank vehicle KWW 38, clutch pipe delivery	30.01.2018	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
171377361	Tank vehicle KWW 39, clutch pipe delivery	30.01.2018	09:30	7,6	colorless, clear	0,70	7,75	0	0	0	0	0	0
171377362	Tank vehicle KWW 40, clutch pipe delivery	30.01.2018	09:55	9,7	colorless, clear	0,67	7,80	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report January 2018**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
171377363	Tank vehicle KWW 41, clutch pipe delivery	30.01.2018	10:00	9,7	colorless, clear	0,57	7,73	0	0	0	0	0	0
171377364	Tank vehicle KWW 42, clutch pipe delivery	30.01.2018	09:45	9,7	colorless, clear	0,67	7,86	0	0	0	0	0	0
171377365	Tank vehicle KWW 43, clutch pipe delivery	30.01.2018	09:40	9,4	colorless, clear	0,66	7,80	0	0	0	0	0	0
171377366	Tank vehicle KWW 44, clutch pipe delivery	30.01.2018	09:20	8,6	colorless, clear	0,61	7,96	0	0	0	0	0	0
171377367	Tank vehicle KWW 45, clutch pipe delivery	30.01.2018	09:25	9,8	colorless, clear	0,70	7,73	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, February 09, 2018