

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report May 2018**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
180421494	Drinking water Delivery Tap 1	30.05.2018	10:00	19,3	colorless, clear	0,22	7,67	0	0	0	0	0	0
180421495	Drinking water Delivery Tap 2	30.05.2018	09:55	19,3	colorless, clear	0,32	7,64	0	0	0	0	0	0
180421496	Drinking water Delivery Tap 3	30.05.2018	09:45	19,5	colorless, clear	0,07	7,72	0	0	0	0	0	0
180421497	Drinking water Delivery Tap 4	30.05.2018	09:40	19,3	colorless, clear	0,32	7,70	0	0	0	0	0	0
180421498	Tank vehicle KWW 33, clutch pipe delivery	30.05.2018	08:45	22,9	colorless, clear	0,26	7,85	0	0	0	0	0	0
180421499	Tank vehicle KWW 34, clutch pipe delivery	30.05.2018	08:30	20,6	colorless, clear	0,05	7,79	0	52	0	0	0	0
180421500	Tank vehicle KWW 35, clutch pipe delivery	30.05.2018	09:25	21,9	colorless, clear	0,49	7,73	0	0	0	0	0	0
180421501	Tank vehicle KWW 36, clutch pipe delivery	30.05.2018	09:00	22,7	colorless, clear	0,48	7,65	0	0	0	0	0	0
180421502	Tank vehicle KWW 37, clutch pipe delivery	30.05.2018	09:05	23,5	colorless, clear	0,33	7,90	0	0	0	0	0	0
180421503	Tank vehicle KWW 38, clutch pipe delivery	30.05.2018	-	-	-	-	-	sampling not possible: tank vehicle in repair shop					
180421504	Tank vehicle KWW 39, clutch pipe delivery	30.05.2018	09:30	25,4	colorless, clear	0,27	7,95	0	0	0	0	0	0
180421505	Tank vehicle KWW 40, clutch pipe delivery	30.05.2018	09:35	20,6	colorless, clear	0,43	7,65	0	0	0	0	0	0

To: Fraport AG, Flughafen Frankfurt Bodenverkehrsdienste



**Report on the samples being taken by our field service - Your Order No.: BVD-4500592804
Report May 2018**

Sample ID	Sample designation	Sampling day	Sampling time	Water temperature °C	Description	Free chlorine mg/l	pH-value	DEV agar after 44 ± 4 h at 20 ± 2°C KBE/ml Limit Value 100	DEV agar after 44 ± 4 h at 36 ± 2°C KBE/ml Limit Value 100	Escherichia coli KBE/100 ml Limit Value 0	Coliforms KBE/100 ml Limit Value 0	Pseudomonas aeruginosa KBE/100 ml Limit Value 0	Enterococci KBE/100 ml Limit Value 0
180421506	Tank vehicle KWW 41, clutch pipe delivery	30.05.2018	08:50	21,1	colorless, clear	0,42	7,68	0	0	0	0	0	0
180421507	Tank vehicle KWW 42, clutch pipe delivery	30.05.2018	07:25	24,7	colorless, clear	0,24	7,90	0	0	0	0	0	0
180421508	Tank vehicle KWW 43, clutch pipe delivery	30.05.2018	09:20	25,1	colorless, clear	0,28	7,83	0	0	0	0	0	0
180421509	Tank vehicle KWW 44, clutch pipe delivery	30.05.2018	09:00	21,9	colorless, clear	0,46	7,75	0	0	0	0	0	0
180421510	Tank vehicle KWW 45, clutch pipe delivery	30.05.2018	08:15	19,0	colorless, clear	0,22	7,52	0	0	0	0	0	0

Assessment:

The microbiological quality of all tested samples is unobjectionable according to German drinking water regulations as far as examined.

SGS INSTITUT FRESENIUS GmbH

Taunusstein, June 06, 2018 _____